

- For Repair of UL Fire Rated Access Doors
- Gasket material is rated to 2,300°F
- Silicone adhesive is UL Classified and Factory Mutual approved
- UL approved gasket and adhesive must be used together to retain the UL listing on your Flame Gard® access panel
- Kit includes enough material to repair 7-16 access doors, depending on door sizes



**GASKET REPAIR KIT**  
**Model No.**  
**750002**

**REPAIR KIT INCLUDES**

- 1 Tube-SIL300 High Temperature Silicone Adhesive, 10.3 oz. Cartridge With Removable Tip
- 1 Roll-High Temperature Silica Cloth Gasket, .090 Thick x 1.5" Width x 50' Length
- 2,300°F Maximum Service Temperature



**SIL300 SILICONE FIRESTOP SEALANT IS:**

 <p>CLASSIFIED UL us 3L73</p>	<p>FILL, VOID OR CAVITY MATERIAL CLASSIFIED BY UNDERWRITERS LABORATORIES INC. © FOR USE IN THROUGH-PENETRATION FIRESTOP SYSTEMS. SEE UL FIRE RESISTANCE DIRECTORY</p> <p>UNDERWRITERS LABORATORIES © CLASSIFIED WALL PROTECTION MATERIAL. SEE PRODUCT CATEGORY IN UL FIRE RESISTANCE DIRECTORY</p> <p>CLASSIFIED FILL, VOID, OR CAVITY MATERIALS FOR USE IN THROUGH-PENETRATION FIRESTOP SYSTEMS. SEE UL DIRECTORY OF PRODUCTS CERTIFIED FOR CANADA AND UL FIRE RESISTANCE DIRECTORY</p>	 <p>FM APPROVED</p>
--	--	---